DISCHARGE CONTROL PANEL PANEL TYP OF (4) SUPPLY

SALES EXAMPLE ONLY NOT FOR CONSTRUCTION

100 GPM @ 600' TDH (260psi) 25 HP 460/3/60 2" x 2" FNPT CONNECTIONS

NO.	DATE	REVISION	BY

VERTICAL CONFIGURATION INLINE BOOSTER PACKAGE CR 20-10

THIS DRAWING AND THE INFORMATION SHOWN HEREON IS THE EXCLUSIVE PROPERTY OF TORRENT ENGINEERING AND EOUPMENT, LIC, AND SHALL NOT BE REPRODUCED OR DISCLOSED TO ANY THIRD PARTY WITHOUT PRIOR WRITTEN CONSENT FROM THE COMPANY.

TORRENT Engineering and Equipment

P.O. BOX 270 MILFORD, IN 46542 Phone: (574)-658-3200 Fax: (574)-658-3229

MILFORD, IN 46542 USA Fax: (574)-658-3229 www.torrentee.com

INLINE BOOSTER PACKAGE				
CR 20-10				
CKID DLAN VIEW				

DRAWN BY: MJH	CHECKED:
DATE: 02-14-2008	APPROVED: JDC

DRAWING NUMBER:

SCALE: NTS

XXXX08-M1

REV: 0 SHEET: 1 OF 1